



Probe insulation resistance
of floors and walls

PRS-1

Accordance with: HD 60364-6 and HD 60364-4-41

| Nominal voltage installations U_n | Testing voltage U_{prob} | Resistance R_{ISO} |
|--|--------------------------------------|--------------------------------|
| $\leq 500 \text{ V}$ | 500 V | 50 k Ω |
| $> 500 \text{ V}$ | 1000 V | 100 k Ω |

